

Addendum "D"

in accordance with Comm 85, Wis. Adm. Code

Attach complete site plan on paper not less than 8 1/2 x 11 inches in size. Plan must include, but not limited to: vertical and horizontal reference point (BM), direction and percent slope, scale or dimensions, north arrow, and location and distance to nearest road.

Please print all information.

Personal information you provide may be used for secondary purposes (Privacy Law, s. 15.04 (1) (m)).

County	Fond du Lac
Parcel I.D.	
Reviewed by	Date

Property Owner Nett Construction, Inc.				Property Location Govt. Lot SW 1/4 NE 1/4 S 29 T 15 N R 18 E (8) XX			
Property Owner's Mailing Address W3880 McCabe Road				Lot # 2	Block #	Subd. Name or CSM# Pheasant Run Subdivision	
City Malone	State WI	Zip Code 53049	Phone Number (920) 921-9076	<input type="checkbox"/> City	<input type="checkbox"/> Village	<input checked="" type="checkbox"/> Town	Nearest Road Pheasant Run

New Construction Use: Residential / Number of bedrooms 3 or 4 Code derived design flow rate 450 to 600 GPD

Replacement Public or commercial - Describe: _____

Parent material Loess/loamy glacial till Flood Plain elevation if applicable Not Applicable ft.

General comments and recommendations: Suggest mound system with 6 to 8 foot wide dispersal cell. Proposed system elevation to be 103.2'.

1 Boring # Boring Pit Ground surface elev. 100.2 ft. Depth to limiting factor 28 in.

Horizon	Depth in.	Dominant Color Munsell	Redox Description Qu. Sz. Cont. Color	Texture	Structure Gr. Sz. Sh.	Consistence	Boundary	Roots	Soil Application Rate	
									GPD/ft ²	
									*Eff#1	*Eff#2
Ap	0-11	10YR 3/3	none	sil	2vfsbk	mfr	as	2fm	0.5	0.8
B1t	11-24	7.5YR 3/4	none	sic1	2fabk	mfr	gw	2fm	0.4	0.6
2B2t	24-28	10YR 4/4	none	grfsl	lmsbk	mvfr	gw	2f	0.4	0.6
2C	28-60	10YR 5/4	c3d 7.5YR 5/8 & 10YR 6/2	fs1	1+2mpl	mvfr	--	1f to 42"	0.0	0.2

2 Boring # Boring Pit Ground surface elev. 103.2 ft. Depth to limiting factor 26 in.

Horizon	Depth in.	Dominant Color Munsell	Redox Description Qu. Sz. Cont. Color	Texture	Structure Gr. Sz. Sh.	Consistence	Boundary	Roots	Soil Application Rate	
									GPD/ft ²	
									*Eff#1	*Eff#2
Ap	0-9	10YR 3/3	none	sil	2fsbk	mfr	as	2fmc	0.5	0.8
Bt	9-19	7.5YR 3/4	none	cl	2fabk	mfr	gw	2fmc	0.4	0.6
C1	19-26	10YR 4/4	none	fs1	lmsbk	mvfr	gw	2f	0.4	0.6
C2	26-56	10YR 5/4	f2d 10YR 5/6+6/2	fs1	1+2mpl	mvfr	--	1f to 38"	0.0	0.2

* Effluent #1 = BOD₅ > 30 < 220 mg/L and TSS > 30 < 150 mg/L

* Effluent #2 = BOD₅ < 30 mg/L and TSS < 30 mg/L

CST Name (Please Print) Dale E. Parker, Ph.D.	Signature <i>Dale E. Parker</i>	CST Number 220870
Address E12325 Lowery Road, La Farge, WI 54639-8052	Date Evaluation Conducted 12-28-00	Telephone Number (608) 625-4033

Property Owner Nett Construction, Inc. Parcel ID # Lot 2, Pheasant Run Subd Page 2 of 3

Boring # Boring
 Pit Ground surface elev. 100.6 ft. Depth to limiting factor 26 in.

Horizon	Depth in.	Dominant Color Munsell	Redox Description Qu. Sz. Cont. Color	Texture	Structure Gr. Sz. Sh.	Consistence	Boundary	Roots	Soil Application Rate	
									GPD/ft ²	
									*Eff#1	*Eff#2
Ap	0-7	10YR 3/3	none	sil	2vfsbk	mfr	as	2fmc	0.5	0.8
Bt	7-16	7.5YR 3/4	none	cl	2fabk	mfr	gw	2fmc	0.4	0.6
C1	16-26	10YR 4/4	none	fsl	1mpl	mvfr	gw	2fm	0.4	0.6
C2	26-54	10YR 5/4	f2d 10YR 6/6+6/3	fsl	2mpl	mvfr	--	1f to 38"	0.0	0.2

Boring # Boring
 Pit Ground surface elev. _____ ft. Depth to limiting factor _____ in.

Horizon	Depth in.	Dominant Color Munsell	Redox Description Qu. Sz. Cont. Color	Texture	Structure Gr. Sz. Sh.	Consistence	Boundary	Roots	Soil Application Rate	
									GPD/ft ²	
									*Eff#1	*Eff#2

Boring # Boring
 Pit Ground surface elev. _____ ft. Depth to limiting factor _____ in.

Horizon	Depth in.	Dominant Color Munsell	Redox Description Qu. Sz. Cont. Color	Texture	Structure Gr. Sz. Sh.	Consistence	Boundary	Roots	Soil Application Rate	
									GPD/ft ²	
									*Eff#1	*Eff#2

* Effluent #1 = BOD₅ > 30 ≤ 220 mg/L and TSS >30 ≤ 150 mg/L
 * Effluent #2 = BOD₅ ≤ 30 mg/L and TSS ≤ 30 mg/L


The Department of Commerce is an equal opportunity service provider and employer. If you need assistance to access services or need material in an alternate format, please contact the department at 608-266-3151 or TTY 608-264-8777.

PARKER & ASSOCIATES, INC.

E12325 LOWERY ROAD
 LA FARGE, WI 54639
 (608) 625-4033

PLOT PLAN

NETT CONSTRUCTION, INC.
 SEC. 29, TOWN OF EMPIRE



POINT	DIST. A→B	OFFSET
B-1	3	9
B-2	63	46
B-3	129	21